

Contractor : Mazen Alawadi & Partners Co. 	Client : Jordan Industrial Ports Company (JIPC)		Consultant: Architect Dhiya Al-halasa office
Project : JIPC-RFP-2023-10 Lubricant Store AQABA - Jordan			
Submission Request			

REF.: CO-NB10-CI-DA-0100-Rev 00 - STEEL STRUCTURE PAINT DATA SHEET

Project Phase : ☐ DE/ Detail Engineering ☒ CO/ Construction ☐ CS/ Commissioning & Start-

Area Code: ☒ NB10 / New Lubricant Store Building

Discipline Code : ☐ AR/ Architecture ☒ CI/ Civil ☐ EL/ Electrical ☐ GE/ General ☐ HE/ HSE ☐ IC/ Instrumentation & Control
☐ ME/ Mechanical ☐ PI/ Piping ☐ GA/ Quality ☐ UR/ Urbanizatio

Document Code :

#	Code	Type of Document	#	Code	Type of Document	#	Code	Type of Document	#	Code	Type of Document
	CC	Calculation		NL	Instrument List		FA	Final Acceptance Certificate		TQ	Technical Query
	MA	Material Approval Request		DS	Final Dossier		RI	Request of Inspection		IL	Instrument list
	CI	Certificates		PL	Pipeline List		FD	Flow Diagram		TS	Technical Specification
	MB	Material Submittal		DW	Drawing		SP	Spare Parts		IP	Inspection and Test Plan
	CL	Check list		PR	Procedure		FS	Site Acceptance test		UL	I/O List
	MR	Monthly Report		EL	Equipment List		ST	Standard Drawings		IR	Interface Information Request
	DA	Date Sheet		PS	Project Schedule		FT	Factory Acceptance test		VL	Vendor List
	MS	Method Statement		EM	Operation Manual		SY	Survey Report		LD	Single Line Diagrams
	DL	Doc./Drawing list		RE	Report		GE	General		WD	Wiring Diagrams

Document Number: 0100

Revision Number: REV. 00

To The Consultant

Description: Kindly check,Submitt & Approve the Attached STEEL STRUCTURE PAINT

Submitted by Contractor's:

NAME: Arch. Rajaa Thaher

SIGNATURE:

DATE: 7/5/2023

Received by Engineer:

NAME: H. Bethge

SIGNATURE:

DATE: 8/5/2023

Engineer Inspection Results:

Inspection Comments :

Please follow the recommended system as mentioned in the data sheet of the primer.

SYSTEM		No. of coats x DFT (microns)
RECOMMENDED SYSTEM To be applied on prepared surface.	ABC Guard Zinc Phosphate Epoxy Primer	1 x 30
	ABC Guard Undercoat H.B	1 x 125
	ABC Guard TOP COAT	1 x 50
	(OR)	
	ABC GUARD 1610	1 x 40

INSPECTION STATUS CODE : ☐ APPROVED (A) ☒ APPROVED AS NOTED (B) ☐ NOT APPROVED (C)

NAME: H. Bethge

SIGNATURE:

DATE: 8/5/2023

RECEIVED BY Contractor:

NAME:

SIGNATURE:

DATE: